



## Water Quality Parameter Monitoring Form

## Lead &amp; Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

Day	Sample Location	pH	Alk	PO4	Other	Y/N	<< Have minimums been met for this day?	PWS ID: 41	Distribution					
9	710 5th Street	7.69	49			Y			0	0	8	9	3	
									System Name: Tillamook Water Dept, City of					
									Sample Period November 2022 Month/Year					
14	710 5th Street	8.24	26			Y			Number of excursions* during this month: 0 ( Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are Cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State					
21	710 5th Street	8.36	27						Minimum Water Quality Parameters as set by State:  pH 7.2 Alk (Alkalinity) Monitoring					
	Well 2	7.91	57											
(No=N=Excursion) Total N's							0	Print Name: Levi Beachy Signature: Date: December 6, 2022						

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>