



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

Day	Sample Location	pH	Alk	PO4	Other	Y/N	<< Have minimums been met for this day?	Distribution					
3	WWTP	7.60	20			Y		PWS ID: 41	0	0	8	9	3
9	WWTP	7.54	17			Y		System Name:	Tillamook Water Dept, City of				
17	WWTP	7.27	37			Y		Sample Period	April 2023 Month/Year				
24	WWTP	7.22	16			Y							
								Number of excursions* during this month: 0 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are Cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State					
								<div>Minimum Water Quality Parameters as set by State:</div> <div><div>pH7.2</div><div>Alk<div>(Alkalinity) Monitoring</div></div></div>					
(No=N=Excursion) Total N's							0	Print Name: Levi Beachy Signature: Date: May 3, 2023					

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>