



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

Day	Sample Location	pH	Alk	PO4	Other	Y/N	<< Have minimums been met for this day?	Distribution					
6	WWTP	7.34	68			Y		PWS ID: 41	0	0	8	9	3
13	WWTP	7.40	57			Y							
								System Name:	Tillamook Water Dept, City of				
								Sample Period	September 2023 Month/Year				
19	WWTP	7.57	66			Y							
								Number of excursions* during this month:	0				
								(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are Cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State					
								<div>Minimum Water Quality Parameters as set by State:</div> <div><div>pH</div><div>7.2</div><div>Alk</div><div></div><div>(Alkalinity) Monitoring</div></div>					
								Print Name:	Levi Beachy				
								Signature:					
								Date:	October 3, 2023				
								Send to DHS within 10 days after end of sampling period					
	OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350												
	Phone (971) 673-0405 Website: http://healthoregon.org/dwp/												
								pg. 1					