



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

Day	Sample Location	pH	Alk	PO4	Other	Y/N
3	WWTP	7.72	37			Y
8	WWTP	7.61	30			Y
15	WWTP	7.66	32			Y
23	WWTP	7.93	35			Y
29	WWTP	7.81	30			Y

<< Have
 minimums
 been met
 for this day?

PWS ID: 41

Distribution

0	0	8	9	3
---	---	---	---	---

System Name: Tillamook Water Dept, City of

Sample Period: July 2024

Month/Year

Number of excursions* during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are Cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State

Minimum Water Quality Parameters as set by State:

pH	7.2	
Alk	20	(Alkalinity) Monitoring

Print Name: Aj Harmon

Signature:

Date: August 1, 2024

(No=N=Excursion) Total N's **0**

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>