



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

Day	Sample Location	pH	Alk	PO4	Other	Y/N
7	WWTP	7.75	38			Y
15	WWTP	7.70	25			Y
19	WWTP	7.97	31			Y
25	WWTP	7.69	27			Y

<< Have minimums been met for this day?
 PWS ID: 41

Distribution

System Name: Tillamook Water Dept, City of

Sample Period: August 2024

Month/Year

Number of excursions* during this month: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are Cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State

Minimum Water Quality Parameters as set by State:

pH
 Alk (Alkalinity) Monitoring

Print Name: Aj Harmon

Signature:

Date: September 3, 2024

(No=N=Excursion) Total N's

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>