



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

Day	Sample Location	pH	Alk	PO4	Other	Y/N
4	WWTP	7.39	60			
12	WWTP	7.35	59			
19	WWTP	7.41	57			
25	WWTP	7.40	56			

<< Have
 minimums
 been met
 for this day?

PWS ID: 41

Distribution

System Name: Tillamook Water Dept, City of

Sample Period: November 2024
 Month/Year

Number of excursions* during this month: 0
 (Over 9 excursions in 6 months is a violation.
 Entry Point and Distribution excursions are
 Cumulative). An 'excursion' is any day in which the
 water quality parameter(s) fall below the minimum
 set by the State

**Minimum Water Quality
 Parameters as set by State:**

pH
 Alk (Alkalinity)
 Monitoring

Print Name: AJ Harmon

Signature:

Date: December 5, 2024

(No=N=Excursion) Total N's

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>