



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

County: Tillamook

Agency: Region 1

Day	Sample Location	pH	Alk	PO4	Other	Y/N
2	WWTP	7.39	58			
9	WWTP	7.33	25			
18	WWTP	7.41	60			
23	WWTP	7.34	64			
30	WWTP	7.28	62			
(No=N=Excursion) Total N's						0

<< Have  
 minimums  
 been met  
 for this day?

PWS ID: 41

**Distribution**

0	0	8	9	3
---	---	---	---	---

**System Name:** Tillamook Water Dept, City of

**Sample Period:** December 2024

Month/Year

**Number of excursions\* during this month:** 0

( Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are Cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State

**Minimum Water Quality Parameters as set by State:**

pH	7.2	
Alk	20	(Alkalinity) Monitoring

**Print Name:** AJ Harmon

**Signature:**

**Date:** January 6, 2025

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>