



Lead & Copper Rule Corrosion Control

Agency: Region 1

Day	Sample Location	pH	Alk	PO ₄	Other	Y/N	<< Have minimums been met for this day?	PWS ID: 41	Distribution					
7	WWTP	7.42	70						0	0	8	9	3	
13	WWTP	7.31	59											
21	WWTP	7.21	52											
27	WWTP	7.66	66											
(No=N=Excursion) Total N's							0							


System Name: Tillamook Water Dept, City of

Sample Period January 2025
Month/Year

Number of excursions* during this month: 0
*(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are Cumulative).* An ‘excursion’ is any day in which the water quality parameter(s) fall below the minimum set by the State

Minimum Water Quality Parameters as set by State:

pH 7.2
Alk 20 (Alkalinity Monitoring)

Print Name: AJ Harmon
Signature: 
Date: February 3, 2025

Send to DHS within 10 days after end of sampling period

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>

pg. 1