



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

Day	Sample Location	pH	Alk	PO4	Other	Y/N	<< Have minimums been met for this day?	Distribution					
								PWS ID: 41	0	0	8	9	3
4	WWTP	8.05	54					System Name:	Tillamook Water Dept, City of				
								Sample Period	February 2025				
									Month/Year				
10	WWTP	7.71	31					Number of excursions* during this month:	0				
								(Over 9 excursions in 6 months is a violation.					
								Entry Point and Distribution excursions are					
								Cumulative). An 'excursion' is any day in which the					
								water quality parameter(s) fall below the minimum					
								set by the State					
18	WWTP	8.27	28					<div>Minimum Water Quality Parameters as set by State:</div> <div><div>pH7.2</div><div>Alk20</div><div>(Alkalinity) Monitoring</div></div>					
24	WWTP	7.47	31										
(No=N=Excursion) Total N's							0						

Print Name: AJ Harmon

Signature:

Date: March 4, 2025

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>