Oregon Health Authority

DHS Oregon Department of Human Services

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

Distribution

PWS ID: 41 0 0 8 9 3

System Name: Tillamook Water Dept, City of

Sample Period October, 2025

Month/Year

Day	Sample Location	pH	Alk	PO4	Other	Y/N
7	WWTP	8.03	37			Y
13	WWTP	8.09	38			Y
20	WWTP	8.03	37			Y
27	WWTP	7.85	64			Y
					(No=N=Excursion) **Total N's**	0

<< Have minimums been met for this day?

Number of excursions* during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are Cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum *set by the State*

Minimum Water Quality Parameters as set by State:

pH 7.2

Alk 20 *(Alkalinity) Monitoring*

Print Name: Austin Harmon

Signature:

Date: November 3, 2025

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: http://healthoregon.org/dwp/

pg. 1