



## Water Quality Parameter Monitoring Form

## Lead &amp; Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

Day	Sample Location	pH	Alk	PO4	Other	Y/N	<< Have minimums been met for this day?		Distribution	
4	WWTP	7.97	36			Y			PWS ID: 41	0 0 8 9 3
13	WWTP	8.03	30			Y			System Name:	Tillamook Water Dept, City of
17	WWTP	8.00	34			Y			Sample Period	November, 2025 Month/Year
24	WWTP	8.22	31			Y			Number of excursions* during this month:	0 ( Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are Cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State
							Minimum Water Quality Parameters as set by State:			
							pH	7.2		
							Alk	20	(Alkalinity) Monitoring	
							Print Name:	Austin Harmon		
							Signature:			
							Date:	December 1, 2025		
(No=N=Excursion) Total N's							0			
Send to DHS within 10 days after end of sampling period										
OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350										
Phone (971) 673-0405 Website: <a href="http://healthoregon.org/dwp/">http://healthoregon.org/dwp/</a>										
pg. 1										