



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

Day	Sample Location	pH	Alk	PO4	Other	Y/N	<< Have minimums been met for this day?		Distribution	
4	WWTP	8.26	30			Y			PWS ID: 41	0 0 8 9 3
8	WWTP	7.62	59			Y			System Name:	Tillamook Water Dept, City of
16	WWTP	7.56	64			Y			Sample Period	December, 2025 Month/Year
22	WWTP	7.59	38			Y			Number of excursions* during this month: 0 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are Cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State	
29	WWTP	7.55	58			Y			Minimum Water Quality Parameters as set by State:	
							pH	7.2		
							Alk	20	(Alkalinity)	
									Monitoring	
							Print Name:	Austin Harmon		
							Signature:			
							Date:	January 5, 2026		
(No=N=Excursion) Total N's							0			
Send to DHS within 10 days after end of sampling period										
OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350										
Phone (971) 673-0405 Website: http://healthoregon.org/dwp/										
pg. 1										