

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

Day	Sample Location	pH	Alk	PO4	Other	Y/N	<< Have minimums been met for this day?	PWS ID: 41	Distribution										
46	WWTP	8.05	23			Y			0	0	8	9	3						
15	WWTP	7.95	29			Y													
21	WWTP	8.00	25			Y													
27	WWTP	7.65	61			Y													
							<p>System Name: Tillamook Water Dept, City of</p> <p>Sample Period: December, 2025 Month/Year</p> <p>Number of excursions* during this month: 0 <i>(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are Cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State</i></p>												
							<p>Minimum Water Quality Parameters as set by State:</p> <table border="1"> <tr> <td>pH</td> <td>7.2</td> <td></td> </tr> <tr> <td>Alk</td> <td>20</td> <td>(Alkalinity) Monitoring</td> </tr> </table>							pH	7.2		Alk	20	(Alkalinity) Monitoring
pH	7.2																		
Alk	20	(Alkalinity) Monitoring																	
							<p>Print Name: Austin Harmon</p> <p>Signature: </p> <p>Date: February 2, 2026</p>												
							<p>(No=N=Excursion) Total N's 0</p>												

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>