

Day	pH	Alk	Phos	Other	Y/N
1	7.80				NO
2	7.90				
3	7.90				
4	7.90				
5	7.90				
6	8.00				
7	7.90				
8	8.00				
9	8.00				
10	7.80				
11	7.50				
12	7.80				
13	7.90				
14	8.00				
15	NO TEST				
16	7.90				
17	7.90				
18	7.90				
19	7.80				
20	7.80				
21	7.80				
22	7.70				
23	8.00				
24	8.00				
25	8.00				
26	7.90				
27	7.90				
28	7.90				
29	7.90				
30	7.80				
31	7.90				

<<Have minimums been met for this day?

County Washington

Agency REGION 1

**ENTRY POINT**

**EP-A**

**PWS ID 4100898**

**TIMBER WATER ASSOCIATION**

Sample period: MARCH 2021  
 Month/Year

Number of excursions during this month: \_\_\_\_\_

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.2

Print Name: Tabata Heidt

Signature: *Tabata Heidt*

Date & Phone#: 04-01-21

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 31