



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.80				N
2	7.80				
3	7.80				
4	7.80				
5	7.80				
6	7.80				
7	7.80				
8	7.80				
9	7.90				
10	7.90				
11	7.90				
12	7.90				
13	7.80				
14	7.80				
15	7.80				
16	7.80				
17	7.80				
18	7.70				
19	7.70				
20	7.80				
21	7.80				
22	7.80				
23	7.80				
24	7.90				
25	7.90				
26	7.90				
27	7.80				
28	7.90				
29	7.80				
30	7.80				
31	7.80				

<<Have minimums been met for this day?

County Washington Agency REGION 1

ENTRY POINT EP-A

PWS ID 4100898
TIMBER WATER ASSOCIATION

Sample period: August 2021
Month/Year

Number of excursions during this month: _____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

—Reference—

Minimum Water Quality Parameter(s) as set by State:

pH 7.2

Print Name: Tabata Heidt
Signature: *Tabata Heidt*
Date & Phone#: 09-02-21

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's