



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

| Day | pH | Alk | Phos | Other | Y/N |
|-----|------|-----|------|-------|-----|
| 1 | 7.90 | | | | NO |
| 2 | 7.90 | | | | |
| 3 | 7.90 | | | | |
| 4 | 7.80 | | | | |
| 5 | 7.80 | | | | |
| 6 | 7.90 | | | | |
| 7 | 7.90 | | | | |
| 8 | 7.90 | | | | |
| 9 | 7.90 | | | | |
| 10 | 7.90 | | | | |
| 11 | 7.90 | | | | |
| 12 | 7.80 | | | | |
| 13 | 7.80 | | | | |
| 14 | 7.90 | | | | |
| 15 | 7.90 | | | | |
| 16 | 7.90 | | | | |
| 17 | 7.90 | | | | |
| 18 | 7.90 | | | | |
| 19 | 7.80 | | | | |
| 20 | 7.80 | | | | |
| 21 | 7.90 | | | | |
| 22 | 7.90 | | | | |
| 23 | 7.90 | | | | |
| 24 | 7.90 | | | | |
| 25 | 7.80 | | | | |
| 26 | 7.80 | | | | |
| 27 | 7.90 | | | | |
| 28 | 7.90 | | | | |
| 29 | 7.90 | | | | |
| 30 | 7.80 | | | | |
| 31 | 7.90 | | | | |

<<Have minimums been met for this day?

County: Washington Agency: REGION 1

**ENTRY POINT
EP-A**

**PWS ID 4100898
TIMBER WATER ASSOCIATION**

Sample period: August 2022
Month/Year

Number of excursions during this month: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.2

Print Name: Tabata Hleudt
Signature: [Signature]
Date & Phone#: 09-01-22

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's