



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.90				No
2	7.80				
3	7.90				
4	7.80				
5	7.80				
6	7.80				
7	7.80				
8	7.90				
9	7.90				
10	7.90				
11	7.90				
12	7.90				
13	7.90				
14	7.80				
15	MAINTENANCE SHUTDOWN				
16	7.80				
17	7.80				
18	7.90				
19	7.80				
20	7.80				
21					
22	REPAIR SHUTDOWN				
23					
24					
25	7.80				
26	MAINTENANCE SHUTDOWN				
27	7.80				
28	7.80				
29	7.80				
30	7.80				
31					

<<Have minimums been met for this day?

County: Washington Agency: REGION 1

ENTRY POINT
EP-A

PWS ID 4100898
TIMBER WATER ASSOCIATION

Sample period: SEPTEMBER - 2022
Month/Year

Number of excursions during this month: _____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference _____

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.2

Print Name: Tabata Heidt
Signature: *Tabata Heidt*
Date & Phone#: 10-03-2022

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's