

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	7.90				N
2	7.90				
3	7.90				
4	7.90				
5	7.80				
6	7.80				
7	7.80				
8	7.80				
9	PLANT SHUTDOWN			REPAIR OUTAGE	
10	7.80				
11	7.80				
12	7.80				
13	7.80				
14	7.70				
15	PLANT SHUTDOWN				
16	PROBLEM W/SPEED PUMPS				
17	7.80				
18	7.90				
19	7.90				
20	7.90				
21	7.90				
22	7.90				
23	7.90				
24	7.90				
25	7.90				
26	7.90				
27	7.90				
28	7.90				
29	7.90				
30	7.90				
31					

<<Have minimums been met for this day?

County: Washington

Agency: REGION 1

**ENTRY POINT**

**EP-A**

**PWS ID 4100898**

**TIMBER WATER ASSOCIATION**

Sample period: November 2022  
 Month/Year

Number of excursions during this month: \_\_\_\_\_

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.2

Print Name: Tabata Heidt  
 Signature: [Signature]  
 Date & Phone#: 12-03-22

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 1