



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.90				N
2	7.90				
3	7.90				
4	7.90				
5	CIP MAINTENANCE				
6	7.90				
7	7.90				
8	7.90				
9	7.90				
10	7.90				
11	7.90				
12	7.90				
13	7.90				
14	7.90				
15	7.90				
16	7.90				
17	7.90				
18	7.90				
19	7.90				
20	7.90				
21	7.90				
22	7.90				
23	7.90				
24	7.90				
25	7.90				
26	7.90				
27	7.90				
28	POWER OUTAGE				
29					
30					
31					

<<Have minimums been met for this day?

County: Washington Agency: REGION 1

**ENTRY POINT
EP-A**

**PWS ID 4100898
TIMBER WATER ASSOCIATION**

Sample period: FEBRUARY 2023
Month/Year

Number of excursions during this month: _____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.2

Print Name: _____

Signature: *[Signature]*

Date & Phone#: 02-01-23

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's