



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

| Day | pH | Alk | Phos | Other | Y/N |
|-----|------|-------------|------|-------|-----|
| 1 | 7.90 | | | | |
| 2 | 7.90 | | | | |
| 3 | 7.90 | | | | |
| 4 | 7.80 | | | | |
| 5 | 7.90 | | | | |
| 6 | 7.80 | | | | |
| 7 | 7.90 | | | | |
| 8 | 7.90 | | | | |
| 9 | 7.90 | | | | |
| 10 | 7.90 | | | | |
| 11 | 7.80 | | | | |
| 12 | 7.80 | | | | |
| 13 | 7.80 | | | | |
| 14 | 7.80 | | | | |
| 15 | 7.80 | | | | |
| 16 | 7.80 | | | | |
| 17 | 7.80 | | | | |
| 18 | 7.80 | | | | |
| 19 | 7.80 | | | | |
| 20 | 7.90 | | | | |
| 21 | 7.80 | | | | |
| 22 | 7.90 | | | | |
| 23 | 7.80 | | | | |
| 24 | 7.80 | | | | |
| 25 | 7.80 | | | | |
| 26 | CIP | MAINTENANCE | | | |
| 27 | 7.80 | | | | |
| 28 | 7.80 | | | | |
| 29 | 7.80 | | | | |
| 30 | 7.80 | | | | |
| 31 | 7.80 | | | | |

(No = N = Excursion) Total N's

<<Have minimums been met for this day?

County: Washington Agency: REGION 1

ENTRY POINT EP-A

PWS ID 4100898
TIMBER WATER ASSOCIATION

Sample period: March 2023
Month/Year

Number of excursions during this month: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.2

Print Name: Tabata Heidt
Signature: [Signature]
Date & Phone#: 04-03-23

Send to DWP within 10 days after end of sampling period