



# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.80				NO
2	7.80				
3	7.80				
4	7.80				
5	7.80				
6	7.80				
7	7.90				
8	7.90				
9	7.90				
10	7.90				
11	7.90				
12	7.90				
13	7.90				
14	7.90				
15	7.90				
16	7.90				
17	7.90				
18	NO TEST	TODAY			
19	7.90				
20	7.90				
21	NO TEST	TODAY			
22	7.90				
23	7.80				
24	7.80				
25	7.80				
26	7.80				
27	7.80				
28	7.80				
29	8.00				
30	8.00				
31	7.90				

(No = N = Excursion) Total N's  

<<Have minimums been met for this day?

County: Washington Agency: REGION 1

**ENTRY POINT**  
**EP-A**

**PWS ID 4100898**  
**TIMBER WATER ASSOCIATION**

Sample period:           MAY 2023            
Month/Year

Number of excursions during this month:             
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.2

Print Name:           Tabata Heidt            
Signature:           *Tabata Heidt*            
Date & Phone#:           06-01-23          

Send to DWP within 10 days after end of sampling period