

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.80				
2	7.80				
3	7.60				
4	7.60				
5	7.40				
6	7.40				
7	7.20				
8	7.20				
9	7.60				
10	7.80				
11	7.80				
12	7.80				
13	7.80				
14	7.80				
15	7.80				
16	7.80				
17	7.80				
18	7.80				
19	7.80				
20	7.80				
21	7.80				
22	7.80				
23	7.80				
24	7.80				
25	7.80				
26	PLANT DOWN				
27	POWER OUTAGE				
28					
29	7.80				
30	7.80				
31	PLANT DOWN MAINTENANCE				

(No = N = Excursion) Total N's

<<Have
minimums
been met for
this day?

County:
Washington

Agency: REGION 1

ENTRY POINT

EP-A

PWS ID 4100898

TIMBER WATER ASSOCIATION

Sample period: DECEMBER - 2024
Month/Year

Number of excursions during this month:


*(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State.*

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.2

Print Name: Tabata, Heidi

Signature: 

Date & Phone#: 01-06-25

Send to DWP within 10 days after end of
sampling period