

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.80				
2	7.80				
3	7.80				
4	7.80				
5	7.80				
6	7.80				
7	7.80				
8	7.80				
9	7.80				
10	7.80				
11	7.80				
12	7.80				
13	7.80				
14	7.80				
15	7.80				
16	POWER OUTAGE				
17	7.80				
18	7.80				
19	7.80				
20	7.80				
21	7.80				
22	7.80				
23	7.80				
24	7.80				
25	7.80				
26	7.80				
27	7.80				
28	7.80				
29	7.80				
30	7.80				
31	7.80				

(No = N = Excursion) Total N's **N**

<<Have
minimums
been met for
this day?

County:
Washington

Agency REGION 1

ENTRY POINT

EP-A

PWS ID 4100898

TIMBER WATER ASSOCIATION

Sample period: JANUARY 2025
Month/Year

Number of excursions during this month: _____

(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH **7.2**

Print Name: Tabata Heidt

Signature: Tabata Heidt

Date & Phone#: 02-04-25

Send to DWP within 10 days after end of
sampling period