

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	7.80				
2	7.80				
3	7.80				
4	7.80				
5	7.80				
6	7.80				
7	7.80				
8	POWER OUTAGE				
9					
10	7.80				
11	7.80				
12	7.80				
13	7.80				
14	7.80				
15	7.80				
16	7.80				
17	7.80				
18	PLANT SHUTDOWN				
19	7.80				
20	7.80				
21	7.80				
22	7.80				
23	7.80				
24	7.80				
25	7.80				
26	7.80				
27	7.80				
28	7.80				
29	7.80				
30	PLANT SHUTDOWN				
31					

(No = N = Excursion) Total N's   

<<Have  
minimums  
been met for  
this day?

County:  
Washington

Agency: REGION 1

**ENTRY POINT**

**EP-A**

**PWS ID 4100898**

**TIMBER WATER ASSOCIATION**

Sample period: April - 2025  
Month/Year

Number of excursions during this month:       

(Over 9 excursions in 6 months is a violation.  
Entry Point and Distribution excursions are  
cumulative). An 'excursion' is any day in which the  
water quality parameter(s) fall below the minimum  
set by the State.

Reference

**Minimum Water Quality  
Parameter(s) as set by State:**

pH 7.2

Print Name: Tabata Heidt  
Signature: *Tabata*  
Date & Phone#: 05-01-25

Send to DWP within 10 days after end of  
sampling period