

Day	pH	Alk	Phos	Other	Y/N
-----	----	-----	------	-------	-----

1	7.80				N
2	7.80				
3	7.80				
4	7.80				
5	7.80				
6	7.80				
7	7.80				
8	7.80				
9	7.80				
10	7.80				
11	7.80				
12	7.80				
13	7.80				
14	7.80				
15	7.80				
16	7.80				
17	7.80				
18	7.80				
19	7.80				
20	7.80				
21	7.80				
22	7.80				
23	7.80				
24	7.80				
25	7.80				
26	7.80				
27	7.80				
28	POWER OUTAGE				
29	7.80				
30	7.80				
31	7.80				

(No = N = Excursion) Total N's **N**

<<Have
minimums
been met for
this day?

County:
Washington

Agency: REGION 1

ENTRY POINT

EP-A

PWS ID 4100898

TIMBER WATER ASSOCIATION

Sample period: August - 2025
Month/Year

Number of excursions during this month: _____

(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH **7.2**

Print Name: Tabata Heidt

Signature: Tabata Heidt

Date & Phone#: 09-05-25

Send to DWP within 10 days after end of
sampling period