



# Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	RAWs	Finish	Y/N
1					
2					
3					
4					
5					
6					
7					
8					
9					
10	7.3		36.6	73.4	Y
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24	7.4		19.7	29.7	Y
25					
26					
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

County: Columbia

Agency: REGION 1

**ENTRY POINT**

**EP-A**

**PWS ID 4100922**

**VERNONIA, CITY OF**

Sample period: February 2021  
Month/Year

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference

**Minimum Water Quality  
Parameter(s) set for this PWS:**

pH 7.3

Print Name: Jeff Bych  
Signature: [Signature]  
Date: 3-8-21

(No = N = Excursion) Total N's 0

Send to DWP within 10 days after end of sampling period

DHS, Drinking Water Program, PO Box 14350, Portland, OR 97293-0350