



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	RAW Alk	Finish	Y/N
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					
16					
17	7.4	28.9	21.6		Y
18					
19					
20					
21					
22					
23					
24	7.4	26.8	16.2		Y
25					
26					
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

County: Columbia Agency: REGION 1

**ENTRY POINT
EP-A**

**PWS ID 4100922
VERNONIA, CITY OF**

Sample period: **March 2021**
Month/Year

Number of excursions during this month: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference
**Minimum Water Quality
Parameter(s) set for this PWS:**
pH 7.3

Print Name: Jeff Buch
Signature: [Signature]
Date: 4-5-21

(No = N = Excursion) Total N's 0

Send to DWP within 10 days after end of sampling period