



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	RAW Alk	Sili	Y/N
1					
2	7.3	36.4	25.7		Y
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					
16	7.3	29.1	32.8		Y
17					
18					
19					
20					
21					
22					
23	7.4	45.3	30.4		Y
24					
25					
26					
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

County: Columbia Agency: REGION 1

**ENTRY POINT
EP-A**

**PWS ID 4100922
VERNONIA, CITY OF**

Sample period: February 2022
Month/Year

Number of excursions during this month: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference
**Minimum Water Quality
Parameter(s) set for this PWS:**
pH 7.3

Print Name: Jeff Buch
Signature: [Signature]
Date: 3-4-22

(No = N = Excursion) Total N's 0

Send to DWP within 10 days after end of sampling period