



# Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	RAW	Finsh	Y/N
1	7.4		29.6	31.7	Y
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14	7.5		33.8	38.9	Y
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28	7.4		31.4	28.9	Y
29					
30					
31					

<<Have minimums been met for this day?

County: Columbia Agency: REGION 1

## ENTRY POINT

### EP-A

### PWS ID 4100922

### VERNONIA, CITY OF

Sample period: Sept. 2022  
Month/Year

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference

**Minimum Water Quality Parameter(s) set for this PWS:**

pH 7.3

Print Name: Jeff Burch

Signature: [Signature]

Date: 10-6-22

(No = N = Excursion) Total N's 0

Send to DWP within 10 days after end of sampling period