

Day	pH	Alk	Phos <sup>C</sup>	Y/N
1				
2				
3	7.3	33.2	28.2	
4				
5				
6				
7				
8				
9	7.3	26.7	23.2	
10				
11				
12				
13				
14				
15				
16	7.3	25.5	20.5	
17				
18				
19				
20				
21				
22				
23	7.5	29.5	26.9	
24				
25				
26				
27				
28				
29				
30	7.4	25.8	19.5	
31				

raw Alk

<<Have minimums been met for this day?

County: Columbia Agency: REGION 1

**ENTRY POINT**

**EP-A**

**PWS ID 4100922**

**VERNONIA, CITY OF**

Sample period: November 2022  
 Month/Year

Number of excursions during this month: \_\_\_\_\_

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.3  
 Alk 20.0 (Alkalinity)

Print Name: CHRIS RICHARDSON

Signature: Ch. RL

Date & Phone#: 12-2-22 (503) 429-6921

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's**