

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6					
7	7.5	28.3	15.3		y
8					
9					
10					
11					
12					
13					
14	7.5	21.3	31.8		y
15					
16					
17					
18					
19					
20					
21	7.4	26.2	20.4		y
22					
23					
24					
25					
26					
27					
28	7.5	27.1	22.0		y
29					
30					
31					

raw Alk

<<Have minimums been met for this day?

County: Columbia Agency: REGION 1

**ENTRY POINT
EP-A**

**PWS ID 4100922
VERNONIA, CITY OF**

Sample period: December 2022
Month/Year

Number of excursions during this month: _____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH	7.3
Alk	20.0 (Alkalinity)

Print Name: CHRIS RICHARDSON

Signature: *CR*

Date & Phone#: 1-4-2023

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's