

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	7.3	27.1			
2					
3					
4					
5					
6					
7					
8	7.4	28.8			
9					
10					
11					
12					
13					
14					
15	7.4	30.8			
16					
17					
18					
19					
20					
21					
22	7.5	29.3			
23					
24					
25					
26					
27					
28					
29					
30					
31					

(No = N = Excursion) **Total N's**

<<Have minimums been met for this day?

County: Columbia Agency: REGION 1

**ENTRY POINT**

**EP-A**

**PWS ID 4100922**

**VERNONIA, CITY OF**

Sample period: Feb 2023  
Month/Year

Number of excursions during this month: \_\_\_\_\_

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH   
Alk  (Alkalinity)

Print Name: CHRIS RICHARDSON

Signature: ehrl

Date & Phone#: 2-28-23 (503)429-6921

Send to DWP within 10 days after end of sampling period