

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12	7.4	75.3			Y
13					
14					
15					
16					
17					
18					
19	7.4	55.9			Y
20					
21					
22					
23					
24					
25					
26	7.3	42.1			Y
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

County: Columbia Agency: REGION 1

**ENTRY POINT**  
**EP-A**  
**PWS ID 4100922**  
**VERNONIA, CITY OF**

Sample period: July 2023  
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH	7.3
Alk	20.0 (Alkalinity)

Print Name: Jeff Berch  
Signature: [Signature]  
Date & Phone#: 8-8-23 - 503-429-6921

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0