

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6					
7					
8					
9	7.4	21.6			Y
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23	7.5	40.6			Y
24					
25					
26					
27					
28					
29					
30	7.3	24.8			Y
31					

<<Have minimums been met for this day?

County: Columbia Agency: REGION 1

ENTRY POINT

EP-A

PWS ID 4100922

VERNONIA, CITY OF

Sample period: August 2023
 Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH

7.3

 Alk

20.0

 (Alkalinity)

Print Name: CHRIS RICHARDSON

Signature: CR

Date & Phone#: 9-8-23 (503)429-6921

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 0