

# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6	7.4	45.6			Y
7					
8					
9					
10					
11					
12					
13	7.4	28.7			Y
14					
15					
16					
17					
18					
19					
20					
21					
22	7.4	34.1			Y
23					
24					
25					
26					
27					
28	7.4	37.7			Y
29					
30					
31					

<<Have minimums been met for this day?

County: Columbia Agency: REGION 1

**ENTRY POINT**

**EP-A**

**PWS ID 4100922**

**VERNONIA, CITY OF**

Sample period: September 2023  
Month/Year

**Number of excursions during this month:** \_\_\_\_\_

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference \_\_\_\_\_

**Minimum Water Quality Parameter(s) as set by State:**

pH	7.3
Alk	20.0 (Alkalinity)

**Print Name:** CHRIS RICHARDSON

**Signature:**

**Date & Phone#:** 10-2-23 (503)429-6921

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's**