

Day	pH	Alk	Phos	Other	Y/N
1	7.4	31.9			y
2					
3					
4					
5					
6					
7					
8	7.4	33.9			y
9					
10					
11					
12					
13					
14					
15					
16	7.4	28.7			y
17					
18					
19					
20					
21					
22	7.4	57.6			y
23					
24					
25					
26					
27					
28					
29	7.4	34.3			y
30					
31					

<<Have minimums been met for this day?

County: Columbia Agency: REGION 1

**ENTRY POINT**

**EP-A**

**PWS ID 4100922**

**VERNONIA, CITY OF**

Sample period: November 2023  
 Month/Year

Number of excursions during this month: \_\_\_\_\_

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH	7.3
Alk	20.0 (Alkalinity)

Print Name: CHRIS RICHARDSON

Signature: *CR*

Date & Phone#: 12-7-23 // (503) 429-6921

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0