

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	7.4	60.1			Y
4					
5					
6					
7					
8					
9					
10					
11	7.4	52.5			Y
12					
13					
14					
15					
16					
17	7.3	73.7			Y
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					
31	7.3	26.3			Y

<<Have minimums been met for this day?

County: Columbia Agency: REGION 1

**ENTRY POINT**

**EP-A**

**PWS ID 4100922**

**VERNONIA, CITY OF**

Sample period: January // 2024  
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.3  
Alk 20.0 (Alkalinity)

Print Name: Jeff Burch  
Signature: [Signature]  
Date & Phone#: 2-9-24 503-429-6921

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0