

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6	7.3	42.3			Y
7					
8					
9					
10					
11					
12					
13	7.4	28.7			Y
14					
15					
16					
17					
18					
19					
20	7.5	23.4			Y
21					
22					
23					
24					
25					
26					
27	7.5	28.4			Y
28					
29					
30					
31					

<<Have minimums been met for this day?

County: Columbia Agency: REGION 1

**ENTRY POINT**

**EP-A**

**PWS ID 4100922**

**VERNONIA, CITY OF**

Sample period: March / 2024  
 Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.3  
 Alk 20.0 (Alkalinity)

Print Name: Jeff Burch

Signature: [Signature]

Date & Phone#: 4-9-24 503-429-6921

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0