

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2	7.3	23.1			Y
3					
4					
5					
6					
7					
8					
9	7.5	21.2			Y
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23	7.5	22.2			Y
24					
25					
26					
27					
28					
29					
30	7.4	23.1			Y
31					

<<Have
minimums
been met for
this day?

County: Columbia Agency: REGION 1

ENTRY POINT

EP-A

PWS ID 4100922

VERNONIA, CITY OF

Sample period: April / 2025
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.3
Alk 20.0 (Alkalinity)

Print Name: CHRIS RICHARDSON

Signature: CR

Date & Phone#: 5-5-25 / 503-429-6921

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's 0