

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4	7.4	55.1			Y
5					
6					
7					
8					
9					
10					
11					
12					
13	7.3	67.6			Y
14					
15					
16					
17					
18					
19	7.4	67.3			Y
20					
21					
22					
23					
24					
25					
26	7.3	49.2			Y
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

County: Columbia Agency: REGION 1

**ENTRY POINT
EP-A**

**PWS ID 4100922
VERNONIA, CITY OF**

Sample period: November 2025
Month/Year

Number of excursions during this month: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).
 An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH

7.3

 Alk

20.0

 (Alkalinity)

Print Name: CHRIS RICHARDSON
 Signature: CR
 Date & Phone#: 12/4/25 429-6921

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's

0
