



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	SIII	Y/N
1					
2					
3	7.6				Y
4	7.7				Y
5	7.7				Y
6	7.6				Y
7	7.7				Y
8					
9					
10	7.6				Y
11	7.7				Y
12	7.6				Y
13	7.6				Y
14	7.6				Y
15					
16					
17	7.4				Y
18	7.4				Y
19	7.3				Y
20	7.5				Y
21	7.5				Y
22					
23					
24					
25	7.5				Y
26	7.6				Y
27	7.6				Y
28	7.5				Y
29					
30					
31					

<<Have minimums been met for this day?

County: Lincoln Agency: REGION 2

**ENTRY POINT
EP- A**

PWS ID 4100925

SW LINCOLN CO WATER DIST

Sample period: June 2023
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.1

Print Name: Zach Forciet
Signature: [Signature]
Date Phone#: 7/10/24 541-547-3315
Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0