



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sill	Y/N
1	7.6				Y
2	7.6				Y
3					
4					
5	7.7				Y
6	7.7				Y
7	7.6				Y
8	7.6				Y
9	7.5				Y
10	7.5				Y
11					
12					
13	7.5				Y
14	7.4				Y
15	7.4				Y
16	7.6				Y
17	7.6				Y
18					
19					
20	7.7				Y
21	7.7				Y
22	7.6				Y
23	7.6				Y
24	7.6				Y
25					
26	7.5				Y
27	7.5				Y
28	7.5				Y
29	7.6				Y
30					
31					

County: Lincoln Agency: REGION 2
ENTRY POINT
EP- A
PWS ID 4100925
SW LINCOLN CO WATER DIST
 Sample period: August 2024
 Month/Year

Number of excursions during this month: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference
 Minimum Water Quality Parameter(s) as set by State:
 pH 7.1

Print Name: Rick McClung
 Signature: R. McClung
 Date Phone#: 9/10/24 541-547-3315
 Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0