



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	SIII	Y/N
1					
2	7.4				Y
3					
4					
5	7.4				Y
6	7.7				Y
7	7.4				Y
8	7.3				Y
9	7.3				Y
10					
11					
12	7.6				Y
13	7.4				Y
14	7.6				Y
15	7.6				Y
16	7.7				Y
17					
18					
19	7.6				Y
20	7.5				Y
21	7.6				Y
22	7.6				Y
23	7.5				Y
24					
25					
26					
27	7.6				Y
28	7.5				Y
29	7.5				Y
30	7.6				Y
31	7.7				Y

(No = N = Excursion) Total N's 0

<<Have
minimums
been met for
this day?

County: Lincoln Agency: REGION 2

ENTRY POINT

EP- A

PWS ID 4100925

SW LINCOLN CO WATER DIST

Sample period: January 2025

Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.1

Print Name: Zach Forster

Signature: [Signature]

Date Phone#: 2/10/25 541-547-3315

**Send to DWP within 10 days after end of
sampling period**

DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://oregon.gov/DHS/ph/dwp/index.shtml>