



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	SIII	Y/N
1	7.7				Y
2	7.6				Y
3	off				
4	off				
5	7.6				Y
6	7.7				Y
7	7.5				Y
8	7.5				Y
9	7.6				Y
10	off				
11	off				
12	7.6				Y
13	7.5				Y
14	7.5				Y
15	7.6				Y
16	7.5				Y
17	off				
18	off				
19	7.5				Y
20	7.6				Y
21	7.4				Y
22	7.7				Y
23	7.6				Y
24	off				
25	off				
26	7.6				Y
27	7.5				Y
28	7.6				Y
29	7.5				Y
30	7.6				Y
31					

<<Have
minimums
been met for
this day?

County: Lincoln Agency: REGION 2

ENTRY POINT

EP- A

PWS ID 4100925

SW LINCOLN CO WATER DIST

Sample period: May 2025

Month/Year

Number of excursions during this month: _____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.1

Print Name: R. M. McElroy
Signature: R. M. McElroy
Date Phone#: 6/1/25 541-547-3315
**Send to DWP within 10 days after end of
sampling period**

(No = N = Excursion) **Total N's** 0

DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://oregon.gov/DHS/ph/dwp/index.shtml>