



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	SIII	Y/N
1					Y
2	7.8				Y
3	7.7				Y
4	7.7				Y
5	7.6				Y
6	7.7				Y
7					
8	7.7				Y
9	7.8				Y
10	7.6				Y
11	7.9				Y
12	7.8				Y
13	7.5				Y
14					
15					
16	7.5				Y
17	7.6				Y
18	7.7				Y
19	7.7				Y
20	7.7				Y
21					
22	7.6				Y
23	7.7				Y
24	7.4				Y
25	7.5				Y
26	7.6				Y
27	7.5				Y
28					
29	7.6				Y
30	7.6				Y
31					

(No = N = Excursion) Total N's 0

<<Have
minimums
been met for
this day?

County: Lincoln Agency: REGION 2

ENTRY POINT

EP- A

PWS ID 4100925

SW LINCOLN CO WATER DIST

Sample period: JUNE 2025

Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.1

Print Name: Rick McElroy

Signature: R. McElroy

Date Phone#: 7/1/25 541-547-3315

**Send to DWP within 10 days after end of
sampling period**

DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://oregon.gov/DHS/ph/dwp/index.shtml>