



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	SIII	Y/N
1	7.8				Y
2					
3	7.2				Y
4	7.4				Y
5	7.8				Y
6	7.6				Y
7	7.7				Y
8	7.3				Y
9	7.4				Y
10	7.5				Y
11	7.5				Y
12	7.3				Y
13	7.7				Y
14	7.6				Y
15	7.4				Y
16					
17					
18	7.7				Y
19	7.3				Y
20	7.5				Y
21	7.5				Y
22	7.3				Y
23					
24	7.3				Y
25	7.2				Y
26	7.4				Y
27	7.3				Y
28	7.3				Y
29	7.3				Y
30					
31					

<<Have
minimums
been met for
this day?

County: Lincoln Agency: REGION 2

ENTRY POINT

EP- A

PWS ID 4100925

SW LINCOLN CO WATER DIST

Sample period: August 2025

Month/Year

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State.*

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.1

Print Name: Rick McChung

Signature: R. McChung

Date 8/3rd

Phone#: 541-547-3315

**Send to DWP within 10 days after end of
sampling period**

(No = N = Excursion) **Total N's** 0

**DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://oregon.gov/DHS/ph/dwp/index.shtml>**