



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	SiI	Y/N
1	7.7				Y
2	7.8				Y
3	7.8				Y
4	7.5				Y
5	7.5				Y
6	7.6				Y
7	7.5				Y
8	7.4				Y
9	7.5				Y
10	7.5				Y
11					
12					
13	7.4				Y
14	7.6				Y
15	7.8				Y
16	7.7				Y
17	7.8				Y
18	7.6				Y
19					
20					
21	7.7				Y
22	7.6				Y
23	7.8				Y
24	7.8				Y
25					
26					
27	7.9				Y
28	7.8				Y
29	7.6				Y
30	7.5				Y
31	7.6				Y

(No = N = Excursion) Total N's 0

<<Have
minimums
been met for
this day?

County: Lincoln Agency: REGION 2

ENTRY POINT

EP- A

PWS ID 4100925

SW LINCOLN CO WATER DIST

Sample period: October 2025

Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.1

Print Name: Bob McQuinn

Signature: R. McQuinn

Date Phone#: 11/4/25 541-547-3315

**Send to DWP within 10 days after end of
sampling period**

DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://oregon.gov/DHS/ph/dwp/index.shtml>