

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1					
2					
3					
4	7.7				Y
5					
6					
7					
8	7.6				Y
9					
10					
11					
12					
13	7.5				Y
14					
15					
16					
17					
18					
19					
20					
21	7.6				Y
22					
23					
24					
25					
26					
27	7.6				Y
28					
29					
30					
31					

<<Have
minimums
been met for
this day?

County: Lincoln Agency: REGION 2

ENTRY POINT

EP-B

PWS ID 4100925

SW LINCOLN CO WATER DIST

Sample period: November 2023
Month/Year

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State.*

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.1

Print Name: Rick McClinton
Signature: R. McClinton
Date Phone#: 12/8/23 541-547-3315
**Send to DWP within 10 days after end of
sampling period**

(No = N = Excursion) **Total N's** 0