



# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	SIII	Y/N
1					
2	7.7				Y
3					
4					
5					
6					
7	7.7				Y
8					
9	7.6				Y
10					
11					
12					
13					
14	7.6				Y
15					
16	7.6				Y
17					
18					
19					
20					
21	7.7				Y
22					
23	7.7				Y
24					
25					
26					
27					
28	7.6				Y
29					
30	7.6				Y
31					

<<Have minimums been met for this day?

County: Lincoln Agency: REGION 2

**ENTRY POINT**

**EP- B**

**PWS ID 4100925**

**SW LINCOLN CO WATER DIST**

Sample period: May 2024  
Month/Year

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

**Reference**

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.1

Print Name: Rick McClung

Signature: [Signature]

Date Phone#: 6/10/24 541-547-3315

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0