



# Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	SIII	Y/N
1	7.6				Y
2					
3					
4					
5					
6	7.7				Y
7					
8	7.6				Y
9					
10					
11					
12					
13	7.7				Y
14					
15	7.7				Y
16					
17					
18					
19					
20	7.6				Y
21					
22	7.6				Y
23					
24					
25					
26					
27	7.7				Y
28					
29	7.6				Y
30					
31					

<<Have minimums been met for this day?

County: Lincoln Agency: REGION 2

**ENTRY POINT**

**EP- B**

**PWS ID 4100925**

**SW LINCOLN CO WATER DIST**

Sample period: August 2024  
Month/Year

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

**Reference**

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.1

Print Name: Rick McCleney  
Signature: R. McCleney  
Date Phone#: 9/10/24 541-547-3315

**Send to DWP within 10 days after end of sampling period**

(No = N = Excursion) Total N's 0